

CERTIFICATE OF ANALYSIS



Issued from:

Choksi Laboratories Limited (Building - 2 "Pasteur")
 Survey No. 9/1, Balaji Tulsiyana Industrial Estate,
 Kumed, Off. M.R. 10 Toll Naka,
 Indore - 452010 (M.P.) INDIA

Issued to: MARTHOMA ACADEMY, INDORE SCHEME NO-114, , VIJAYA NAGAR Indore, Madhya Pradesh India - 452001	CoA ID: 01700519/22-23 Report No.: 01700519/22-23 (v1) Issue date: 30-07-2022 Customer Ref(s): N/M Customer ID: M 220048
Sample Name: RO WATER Manufacture License No: N/M Manufacturer Name: N/M Manufacturing Date: N/M Reference of Letter: N/M Date of Letter: N/M Date of Receipt: 13-07-2022 Batch Number: N/M Batch Size: N/M A.R. Number: N/M Expiry / Retest Date: N/M	Sample Quantity: 2*5 LITRE Sealed / Unsealed: Unsealed Packing: PLASTIC CAN Analysis Start Date: 14-07-2022 Analysis End Date: 29-07-2022 Sampling Date: N/M Sampled By: Client Sampling Location: N/M Page Number: 3 of 3

Test specification as per IS 10500:2012 (Amendment-4)

Sr.No.	Characteristics	Unit	Result	Specification	MDL	Reference Method	Permissible Limits
10.	Nickel, as Ni	mg/L	Below Detection Limit	NMT 0.02	0.00510	APHA 3125B	No relaxation
11.	Silver, as Ag	mg/L	Below Detection Limit	NMT 0.1	0.00510	APHA 3125B	No relaxation
12.	Lead, as Pb	mg/L	Below Detection Limit	NMT 0.1	0.00510	APHA 3125B	No relaxation
13.	Zinc, as Zn	mg/L	0.01	NMT 5	0.00510	APHA 3125B	NMT 15
14.	Total Chromium, as Cr						
(i).	Total Chromium, as Cr	mg/L	Below Detection Limit	NMT 0.05	0.00510	APHA 3125 B	No relaxation
15.	Aluminium, as Al	mg/L	0.01	NMT 0.03	0.00510	APHA 3125B	NMT 0.2

Sr.No.	Characteristics	Unit	Result	Specification	MDL	Reference Method	Permissible Limits
Biological							
1.	Escherichia coli	in 100 mL	Not detected	Should not be detected	N/M	IS:15185-2016	Should not be detected
2.	Total Coliform	in 100 mL	Not detected	Should not be detected	N/M	IS:15185:2016	Should not be detected

[End of Report]

Remarks:

1. Test report shall not be reproduced either in part or in full, without written approval of CLL Management.
2. CLL does not give any opinion or interpretation of the same.
3. Sample not Drawn by CLL representative
4. Sample information as Furnished by Customer
5. pH value is reported as at 25 °C.
6. MDL Refer to Method Detection Limit
7. It is recommended that the acceptable limit (specification) is to be implemented values in excess of those mentioned under acceptable render the water not suitable, but still may be tolerated in the absence of an alternative source but up to the limits indicated under 'permissible' limit in the absence of alternate source. , above which the source will have to be rejected.
8. Free Residual Chlorine Limit To be applicable only when water is chlorinated.
9. Subject to terms and conditions mentioned at the end of the CoA.



IDR00336
30-07-2022 11:50:19

Authorised Signatory

IDR01250
30-07-2022 11:51:42

QA Approver